



BATAAN PENINSULA STATE UNIVERSITY

City of Balanga 2100 Bataan


Philippines

PHYSICAL PLANT AND ENGINEERING SERVICES

BID BULLETIN FOR Repair and Rehabilitation of Academic Building II at Dinalupihan Campus

1. Term of Reference and Technical specifications (see attached)
 - a. Sec. 1 - Updated General Scope of Work
 - b. Sec. 5 – Additional Bidding Documents requirements
2. **Thickness and capacity of elevated stainless water tank**
 - a. **Capacity: 3000 gal**
 - b. **Upper layer and cap: 2.0mm**
 - c. **Bottom and first layer: 2.5mm**
 - d. **6 post stainless pipe at 2 inches diameter with braces of 1-inch stainless pipe**
3. Electrical Plans (see attached)
4. PCAB requirements
 - At least Small B, License category of C & D
5. Safety Officer and First Aider can be represented by one person or two persons

Prepared by:


Ar. Roxette S. Umerez, uap

BPSU, TWG Head for Infrastructure

Noted by:


Dr. Alfredo D. Valentos, PME

PPES Director